

Operational Reactor Safety

22.091/22.903

Lecture 18

Pilgrim Nuclear Power Station Background Information

Mark Santiago – Pilgrim Training

Welcome to Pilgrim Station and the Chiltonville Training Center

Source unknown. All rights reserved. This content is excluded from our Creative Commons license.
For more information, see <http://ocw.mit.edu/fairuse>


Pilgrim Station Facts

- 700 MWe Boiling Water Reactor
- 2028 MWth
- Nominal Operating pressure 1030 psig
- 145 control rods
- 580 fuel bundles
- Mark 1 Containment

Pilgrim Station Facts


- Went commercial in 1972
- License will currently expire in Aug 2012
- Application for 20 Year license renewal submitted
 - Expect approval later in 2008.
- Operates on a 24 month refueling cycle
- Owned by Entergy
- Part of a twelve unit nuclear fleet
- Entergy has filed for a permit for new BWR in Mississippi.

Pressurized Water Reactor




Source unknown. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <http://ocw.mit.edu/fairuse>.

Boiling Water Reactor




Source unknown. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <http://ocw.mit.edu/fairuse>.

Reactor and Turbine Buildings



Source unknown. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <http://ocw.mit.edu/fairuse>.

Source unknown. All rights reserved. This content is excluded from our Creative Commons license.
For more information, see <http://ocw.mit.edu/fairuse>.




Reactivity Coefficients

- Void Coefficient
($\sim -1 \times 10^{-3} \Delta k/k / \% \text{ Voids}$)
- Moderator Temperature Coefficient
($\sim -1 \times 10^{-4} \Delta k/k / ^\circ\text{F}$)
- Doppler Coefficient
($\sim -1 \times 10^{-5} \Delta k/k / ^\circ\text{Fuel Temperature}$)

REACTOR CONTROL

POS POS ON A CH B		RMCS	ATWS	ATS	PEIOS	NEUTRON MONITORING
1	2	3	4	5	6	7
8	9	10	11	12	13	14
15	16	17	18	19	20	21
22	23	24	25	26	27	28
29	30	31	32	33	34	35
36	37	38	39	40	41	42
43	44	45	46	47	48	49
50	51	52	53	54	55	56
57	58	59	60	61	62	63
64	65	66	67	68	69	70
71	72	73	74	75	76	77
78	79	80	81	82	83	84
85	86	87	88	89	90	91
92	93	94	95	96	97	98
99	100	101	102	103	104	105



Source unknown. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <http://ocw.mit.edu/fairuse>

Source unknown. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <http://ocw.mit.edu/fairuse>.





Source unknown. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <http://ocw.mit.edu/fairuse>

SCOOP TUBE
RESET B

RESET



FIELD BRKR

CAUTION
1-CYCLE-18 CAUTION-00281
282-0158
REACTOR SAFETY SYS LOCK W/ DISTR.
CONTROL LAMP #1
DO NOT CHANGE TAG OR REMOVE GUIDE SPRING


262-0253
88.5 PCT



OUTBD ISOL VLV
FC AO-220-45



Critical Power



Critical Power Ratio (CPR)

$$\text{CPR} = \frac{\text{CP}}{\text{AP}} > 1.0$$


Where:

CPR = critical power ratio

CP = bundle power at which OTB occurs

AP = actual bundle power

MCPR LIMITS



PURPOSE

RADIOACTIVE RELEASE FROM THE PLANT WITHIN LIMITS

FAILURE MECHANISM

FUEL CLADDING CRACKING DUE TO HIGH STRESS

GROSS CLADDING FAILURE DUE TO LACK OF COOLING

FUEL CLADDING CRACKING DUE TO LOSS OF COOLING

CAUSE OF FAILURE

FUEL PELLET EXPANSION

DECAY HEAT AND STORED HEAT FOLLOWING LOCA

LOSS OF NUCLEATE BOILING AROUND CLADDING

LIMITING CONDITION

1% PLASTIC STRAIN ON CLADDING

CLAD TEMPERATURE 2200°F

BOILING TRANSITION

ITEM MEASURED

LOCAL FUEL PIN POWER IN NODE

AVERAGE FUEL PIN POWER IN NODE

TOTAL FUEL BUNDLE POWER

LIMITING OPERATION

FULL POWER

LOCA

TRANSIENT OPERATION

LIMITING PARAMETER

LHGR

APLHGR

CPR

CALCULATED PARAMETER

FLPD < 1.0

MAPRAT < 1.0

MFLCPR < 1.0

CORE PARAMETERS			PILGRIM CYCLE 17	SEQUENCE NO 2
POWER	MWT	2015.7	3DM/P11	6-MAR-2008 06:40 CALCULATED
POWER	MWE	716.5	PERIODIC LOG	6-MAR-2008 06:40 PRINTED
FLOW	MLB/HR	59.273	USER REQUEST	CASE ID FMLD1080306064009
FPAPDR		0.656	CALC RESULTS	RESTART FRFD1080306062454
SUBC	BTU/LB	27.58	Keff	LPRM SHAPE - FULL CORE
PR	PSIa	1045.75	XE WORTH %	LOAD LINE SUMMARY
CORE	MWD/sT	23308.1	XE/RATED	CORE POWER
CYCLE	MWD/sT	3181.3	AVE VF	CORE FLOW
MCPR		1.712	FLLLP	LOAD LINE
				99.4%
				85.9%
				110.5%

CORRECTION FACTORS: MFLCPR= 1.002 MFLPD= 0.996 MAPRAT= 0.996 ZBB= 3.19
 OPTION: ARTS 2 LOOPS ON MANUAL FLOW MCPRLIM= 1.460 FCBB= N/A

MOST LIMITING LOCATIONS (NON-SYMMETRIC)

MFLCPR	LOC	MFLPD	LOC	MAPRAT	LOC	PCRAT	LOC
0.855	29-22	0.652	25-20-11	0.713	29-22-10	0.956	35-26-11
0.845	29-18	0.651	29-22-10	0.689	31-24-11	0.954	27-18-11
0.841	31-24	0.642	25-22-10	0.688	29-18-11	0.951	27-22-10
0.840	35-24	0.640	35-26-11	0.687	35-24-11	0.935	29-20-10
0.823	27-16	0.639	27-18-11	0.674	27-16-11	0.927	31-26-11
0.822	31-16	0.637	33-28-11	0.674	37-26-10	0.920	27-20-11
0.822	39-16	0.633	29-20-10	0.672	31-16-11	0.905	33-24-11
0.819	37-14	0.630	31-24-11	0.669	37-22-10	0.898	19-26-11
0.818	37-26	0.630	29-18-11	0.657	37-14-10	0.892	31-22-11
0.813	37-22	0.629	35-24-11	0.655	35-12-10	0.889	31-18-11

SEQ.	A1	C=MFLCPR	D=MFLPD	M=MAPRAT	P=PCRAT	*=MULTIPLE	CORE	AVE	AXIAL
							NOTCH	REL PW	LOC
51							00	0.140	24
47							02	0.249	23
L							04	0.764	22
43			10				06	0.886	21
39							08	0.986	20
L							10	1.013	19
35		08			08		12	1.029	18
31							14	1.061	17
L							16	1.026	16
27	10		08			10	18	1.070	15
23					P		20	1.254	14
L							22	1.313	13
19		08	D	*		08	24	1.388	12
15							26	1.434	11
L							28	1.419	10
11			10				30	1.379	09
07							32	1.332	08
L							34	1.243	07 <-
03							36	1.157	06
							38	1.078	05
							40	0.950	04
							42	0.783	03
							44	0.632	02
							46	0.415	01

	L	L	L	L	L	L	L	L	L				
	02	06	10	14	18	22	26	30	34	38	42	46	50
CORE AVERAGE													
RADIAL POWER													
DISTRIBUTION													
RING #	1	2	3	4	5	6	7						
REL PW	0.899	1.395	1.346	1.269	1.226	1.120	0.563						

Abnormal Operational Transients

- Abnormal Operating Transients include the events following a single equipment malfunction or a single operator error that is reasonably expected during the course of planned operations.
- Power failures, pump trips, and rod withdrawal errors are typical of the single malfunctions or errors initiating the events in this category.

Reactor Limits

- To avoid the unacceptable safety results for abnormal operational transients, reactor operating limits are specified. Operating limits are specified to maintain adequate margin to the onset of boiling transition and failure due to cladding strain (CPR & LHGR). To ensure that adequate margin is maintained and an unacceptable result is avoided, a design requirement based on a statistical analysis was selected. This requirement would ensure that during an abnormal operational transient, 99.9% of the fuel rods would be expected to avoid boiling transition.

Abnormal Operational Transients Event Categories

- **Events Resulting in a Nuclear System Pressure Increase**
 - Ex: Turbine trip (turbine stop valve closure)
- **Events Resulting in a Reactor Vessel Water Temperature Decrease**
 - Ex: Inadvertent Pump Start
- **Events Resulting in a Positive Reactivity Insertion**
 - Ex: Continuous, inadvertent rod withdrawal

Abnormal Operational Transients Event Categories Cont.

- **Events Resulting in a Reactor Vessel Coolant Inventory Decrease**
 - Ex: Loss of feedwater flow
- **Events Resulting in a Core Coolant Flow Decrease**
 - Ex: Recirculation pump seizure
- **Events Resulting in a Core Coolant Flow Increase**
 - Ex: Recirculation Flow Control Failure - Increasing Flow

DESIGN BASIS ACCIDENTS


- A design basis accident is a hypothesized accident; the characteristics and consequences of which are utilized in the design of those systems and components pertinent to the preservation of radioactive materials barriers, and the restriction of radioactive material release from the barriers.

Unacceptable Results

- radioactive material release which results in dose consequences that exceeds the guideline values of 10CFR100
- failure of fuel cladding which would cause changes in core geometry such that core cooling would be inhibited
- nuclear system stress in excess of those allowed for the accident classification by applicable codes
- containment stresses in excess of those allowed for the accident classification by applicable industry codes when containment is required
- overexposure to radiation of station personnel in the control room

DESIGN BASIS ACCIDENTS

- **Control Rod Drop Accident**
- **Loss of Coolant Accident**
- **Main Steam Line Break Accident**




Source unknown. All rights reserved.
 This content is excluded from our Creative Commons license.
 For more information, see <http://ocw.mit.edu/fairuse>.

PRIMARY AND SECONDARY CONTAINMENT SYSTEMS
 FIGURE 1 REV. 1

Source unknown. All rights reserved. This content is excluded from our Creative Commons license.
For more information, see <http://ocw.mit.edu/fairuse>.



Source unknown. All rights reserved. This content is excluded from our Creative Commons license.
For more information, see <http://ocw.mit.edu/fairuse>.




Minus a few hundred
thousand gallons of
water...

**T
O
R
T
U
S**

Drywell

- Steel ASME Code pressure vessel
- Shaped like an inverted light bulb



Design Pressure
+ 56 psig

- 2 psig

110% overpressure

+ 62 psig


Design Temp (Tsat)
281°F.

110' Tall

Pressure Suppression Chamber and Pool

Energy Transfer Paths

- Relief valve discharge piping
- HPCI
- RCIC
- Drywell Vent system
- Residual Heat Removal



Hydrogen Event At TMI

- The first warning of the presence of hydrogen in the system was quite violent, but thanks to the heavily over engineered containment structure, it was almost anticlimactic save for its implications. A poorly shielded relay sparked, detonating the hydrogen in the containment. Containment building pressure zoomed to a frightening 28 pounds per square inch, and stayed there for nearly eight seconds as the hydrogen burned. The force shook the control room floor noticeably, and was thought to be equivalent to the explosion of several modern 1,000 pound bombs.


Hydrogen Combustion

The Burn

- Deflagrations are combustion waves which heat the gas by thermal conduction
- Travel Subsonically and cause low pressure loads on the containment

Hydrogen Event At TMI

Burnt crane controls



Source unknown. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <http://ocw.mit.edu/fairuse>.

Hydrogen Combustion

The Boom

- Detonation heats the unburned gas by compression from shock waves.
- The waves travel supersonically and produce high pressure loads on the containment.

Containment Damage


- Hydrogen can create excessive drywell pressure
- Containment design pressure =
- 56 psi
- Estimated failure pressure =
- ~ 200 psi
- Estimated pressure with 30% metal-water reaction with a burn
- >> 200psi

Hydrogen Event At TMI 'Nuf said'



Source unknown. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <http://ocw.mit.edu/fairuse>.

Source unknown. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <http://ocw.mit.edu/fairuse>.



Drywell head



Source unknown. All rights reserved. This content is excluded from our Creative Commons license. For more information, see <http://ocw.mit.edu/fairuse>.

MIT OpenCourseWare
<http://ocw.mit.edu>

22.091 Nuclear Reactor Safety
Spring 2008

For information about citing these materials or our Terms of Use, visit: <http://ocw.mit.edu/terms>.